



SAMPLE PLACARD FOR ALTERNATE POWER SOURCE

This is a sample placard required when there is an alternate source of power connected to the premises wiring system. Specify the type of generation, such as stationary engine generator, solar photovoltaic (PV) array, wind turbine, batteries, fuel cell, etc. The placard must be metal or plastic, with engraved or machine printed letters in a contrasting color, and must include the location of the service point, utility meter, AC and DC disconnects, inverter, and PV array, generator, or other type of generation source, and a footprint of the entire building and site. The placard shall be attached to the service disconnect with pop-rivets, machine screws, or other fasteners as approved by the County of San Diego, Building Division. Epoxy is not an acceptable method of securing the placard.

CAUTION

POWER TO THIS BUILDING IS ALSO SUPPLIED
FROM THE FOLLOWING SOURCES WITH
DISCONNECTS LOCATED AS SHOWN:

